


Corrigendum-II on pre-bid queries

Ref.: NIT No.: NIT / OPTCL /BharatNet-Phase-II/468 Dated 25.06.2018-BharatNet Phase-II Project					
S. No.	Section No.	Clause No.	Reference/Subject	Clarification Sought	OPTCL Reply/Clarification/Amendment
20	IV-Technical Specification	Annexure A-2	2. Aerial OF Cable (ADSS Cable): 24/48 pair ADSS (Type III A) on power lines: As per TEC GR No. TEC/GR/TX/OFC-022/02/MAR-17 with latest amendments if any.	As per TEC GR No. TEC/GR/TX/OFC-022/02/MAR-17 outer sheath of the OFC shall be Anti-Track PE which shall comply TEC/GR/TX/ORM-001/05/DEC-17 which is under discussion at TEC authority for some technical parameters, as no supplier is complying the TEC GR for anti-track outer sheathing material due to which no supplier is CACT approved till now. Hence, for Anti Track Material, we suggest to go with Old ORM "TEC GR No. TEC/GR/TX/ORM-01/04/SEP-09 with amendment issued on 28.03.2013". The same has been adopted in other govt. tender floated under BharatNet Project. So for Anti Track Material, can we go ahead with TEC GR No. TEC/GR/TX/ORM-01/04/SEP-09 with amendment issued on 28.03.2013? Please confirm.	Accepted.
21	IV-Technical Specification	Annexure A-2	2. Aerial OF Cable (ADSS Cable): 24/48 pair ADSS (Type III A) on power lines: As per TEC GR No. TEC/GR/TX/OFC-022/02/MAR-17 with latest amendments if any.	In other govt. tender, OFC Manufacturer have applied for the ADSS Type III-A TSEC against the TEC GR No. TEC/GR/TX/OFC-022/02/MAR-17 with Outer sheath (Anti-Track PE) complying TEC GR No. TEC/GR/TX/ORM-01/04/SEP-09 with amendment issued on 28.03.2013. We understand the same QF-103 shall be considered for the eligibility and TSEC received against the QF-103 shall be applicable for eligibility and Supply for this tender as well.	Accepted.


 CGM (Telecom)
 OPTCL